



**QUALITY ASSURANCE & SAFETY**

TOM DEMKE

UNIVERSITY OF WISCONSIN - SPACE SCIENCE & ENGINEERING CENTER





# Process Quality

- SSEC quality processes to be used for NIR
- Described in PMP (SALT-3501BP0001)
- Processes designed to be compliant with ISO9001

| Document # | Topic                                       |
|------------|---------------------------------------------|
| 1008-0002  | Document Control                            |
| 1008-0004  | Change Control                              |
| 1008-0005  | Training                                    |
| 1008-0006  | Test Equipment Calibration                  |
| 1008-0007  | Project Life Cycle Process (Design Control) |
| 1008-0012  | Complaint Handling                          |
| 1008-0014  | Project Safety                              |
| 1008-0017  | Quality Records                             |
| 1008-0021  | Software Development                        |
| 1008-0024  | Project Management Plan                     |



# Configuration Management



- Document Control
  - SSEC procedure 1008-0002
  - Uses SALT document numbering convention (e.g. SALT-3501BP0001)
  - Project specific document templates developed
  - Documents viewable thru SSEC document & RSS-NIR websites
- Change Control (ECN procedure)
  - SSEC procedure 1008-0004
  - Used for updating released documents or designs
  - Requires same functions approve updates
  - Assesses impact of change on cost, schedule, design, documents, etc.



# Configuration Management (cont.)



- Hardware
  - Controlled thru document & change control processes
  - List of configuration items traceable to model/serial identifiers
  - Parts lists to be maintained for all assemblies in doc control system
- Software
  - Content traceability (to release version)
  - Control of releases
  - Identification of software in use



# Safety



- SSEC procedure 1008-0014
- FMEA-based Hazard Analysis
  - Assesses, scores & identifies mitigation to potential risks
  - Human safety, major equipment, environmental & regulatory risks
  - Started early in development
    - Incorporate safety mitigations early in design process
    - Get design staff thinking about safety early in project
  - Mitigations
    - Design changes
    - Training
    - Inspections
    - Operations, PM & service procedures



# Safety (cont.)



- Hazard Analysis draft
  - Reviewed w/ engineering staff & lead scientist

| ITEM                                    | POTENTIAL HAZARD           | FAILURE CAUSE                                                                | INITIAL RISK |      |     |     | Failure Class | MITIGATION                                                                                                                        | RESIDUAL RISK |      |     |     | EVIDENCE                                                                                                  | REQUIREMENTS | STATUS          | COMMENTS                                                                                                                       |
|-----------------------------------------|----------------------------|------------------------------------------------------------------------------|--------------|------|-----|-----|---------------|-----------------------------------------------------------------------------------------------------------------------------------|---------------|------|-----|-----|-----------------------------------------------------------------------------------------------------------|--------------|-----------------|--------------------------------------------------------------------------------------------------------------------------------|
|                                         |                            |                                                                              | Sev          | Prob | Det | RPN |               |                                                                                                                                   | Sev           | Prob | Det | RPN |                                                                                                           |              |                 |                                                                                                                                |
| <b>NEAR INFRARED SPECTROGRAPH (NIR)</b> |                            |                                                                              |              |      |     |     |               |                                                                                                                                   |               |      |     |     |                                                                                                           |              |                 |                                                                                                                                |
| 1.1                                     | CHEMICAL - Incompatibility | Heat transfer fluid used in glycol cooling loop incompatible with instrument | 2            | 6    | 2   | 24  | S             | Verify cooling loop mix and additives are compatible with all materials that they comes in contact with.                          | 1             | 6    | 1   | 6   | Verify compatibility of cooling loop fluid                                                                |              | Open - evidence |                                                                                                                                |
| 1.2                                     |                            | Lenses and index matching fluids                                             | 4            | 6    | 1   | 24  | Q             | Verify that all of the index matching fluids are compatible with the lenses and other materials that they come in contact with.   | 1             | 6    | 1   | 6   | Verify compatibility of index matching fluid                                                              |              | Open - evidence |                                                                                                                                |
| 1.3                                     |                            | Hygroscopic Lens materials                                                   | 3            | 6    | 1   | 18  | Q             | Verify that all hygroscopic lenses are buffered from the atmosphere by dry index matching fluids, other lenses or purged dry air. | 1             | 6    | 1   | 6   | Verify hygroscopic lenses are protected                                                                   |              | Open - evidence |                                                                                                                                |
| 1.4                                     |                            | Cryotiger gas is incompatible with optics or other NIR materials             | 3            | 6    | 1   | 18  | Q             | Verify the cryotiger gas is compatible with the instrument materials it will contact                                              | 1             | 6    | 1   | 6   | Verify compatibility of cryotiger gas                                                                     |              | Open - evidence | How complicated & costly is this to implement?                                                                                 |
| 1.5                                     |                            | Heat transfer fluid in pre-dewar cooling loop is compatible with instrument  | 3            | 6    | 1   | 18  | Q             | Verify the heat transfer fluid is compatible with the instrument materials it will contact                                        | 1             | 6    | 1   | 6   | Verify compatibility of heat transfer fluid                                                               |              | Open - evidence |                                                                                                                                |
| 1.6                                     | CHEMICAL - Toxicity        | Heat transfer fluid used in cooling loops toxic to users                     | 3            | 3    | 2   | 18  | S             | Verify the material is non-toxic or handling procedures are in place                                                              | 3             | 2    | 2   | 12  | Verify heat transfer fluid is non-toxic                                                                   |              | Open - evidence | If the material is non-toxic the residual risk is 1, 3, 2. If handling procedures are used, then the residual risk is 3, 2, 2. |
| 1.7                                     |                            | Cryotiger cooling gas leak                                                   | 3            | 3    | 2   | 18  | S             | Verify the cryotiger cooling gas does not present a hazard in case of a leak.                                                     | 1             | 3    | 2   | 6   | Verify handling procedures for cryotiger gas                                                              |              | Open - evidence |                                                                                                                                |
| 1.8                                     |                            | Purge gas asphyxiation                                                       | 4            | 4    | 2   | 32  | S             | Verify the purge gas is dry air, and not N2. If any N2 is used, O2 monitoring must be used when working in the enclosure.         | 1             | 4    | 2   | 8   | Add O2 monitoring for N2 purge gas                                                                        |              | Open - evidence | If air is used the residual risk is 1, 4, 2. If N2 is used with an oxygen monitor, then the residual risk is 4, 2, 1.          |
| 1.9                                     |                            | Index matching fluid leaks from bladder                                      | 3            | 3    | 2   | 18  | S             | Verify the material is non-toxic or handling procedures are in place                                                              | 3             | 2    | 2   | 12  | Verify index matching fluid id non-toxic                                                                  |              | Open - evidence | If the material is non-toxic the residual risk is 1, 3, 2. If handling procedures are used, then the residual risk is 3, 2, 2. |
| 1.10                                    |                            | Dry CO <sub>2</sub> cleaning of optics                                       | 4            | 4    | 2   | 32  | S             | O2 monitoring must be used when cleaning the optics w/ dry CO <sub>2</sub> .                                                      | 4             | 2    | 1   | 8   | See 1.8                                                                                                   | See 1.8      | CLOSED          | Probably would need to be completed every 2 years.                                                                             |
| 1.11                                    |                            | Lens coupling fluid potentially toxic                                        | 3            | 3    | 2   | 18  | S             | The proposed lens coupling fluid is nonflammable                                                                                  | 0             | 0    | 0   | 0   | Eliminated                                                                                                |              | ELIMINATED      | Cargille Laser Liquid (cat # 20109) is proposed.                                                                               |
| 2.1                                     | ELECTRICAL - Shock         | Exposed connections / terminals                                              | 4            | 4    | 2   | 32  | S             | Proper termination of all wires, and guards where there are live connections >36 VAC or VDC.                                      | 4             | 1    | 2   | 8   | Inspect for guards on connections > 36 V                                                                  |              | Open - evidence |                                                                                                                                |
| 2.2                                     |                            | Cable failure                                                                | 4            | 2    | 3   | 24  | S             | Proper cable selection with respect to voltage, current, temperature, and bend radius.                                            | 4             | 1    | 3   | 12  | Verify cables rated for use and load                                                                      |              | Open - evidence |                                                                                                                                |
| 2.3                                     |                            | Underrated cables                                                            | 4            | 2    | 3   | 24  | S             | See 2.2                                                                                                                           | 4             | 1    | 3   | 12  | See 2.2                                                                                                   | See 2.2      | CLOSED          |                                                                                                                                |
| 2.4                                     |                            | Inadequate ground                                                            | 4            | 3    | 3   | 36  | S             | Design, installation verification                                                                                                 | 4             | 2    | 1   | 8   | Verify the NIR, tracker, facility & other equipment are adequately grounded together at installation & PM |              | Open - evidence | Detectable through electrical measurements                                                                                     |
| 2.5                                     |                            | Ground for tracker & NIR at different potentials                             | 4            | 3    | 3   | 36  | S             | Verify the NIR, tracker, facility & other equipment are adequately grounded together at installation & PM                         | 4             | 2    | 1   | 8   | See 2.4                                                                                                   | See 2.4      | CLOSED          | Detectable through electrical measurements                                                                                     |



# Design Control



- SSEC procedure 1008-0007 (project life cycle process)
- Defines development process thru system commissioning
- Design Reviews planned
  - Preliminary Design Review - *completed*
  - Critical Design Review
  - Test Readiness Review
  - Pre-Ship Review
  - Pre-Installation Readiness Review
  - Commissioning Review
- Goals/deliverables defined for each design review
  - See PMP for a listing of each design review's deliverables